

06/19/2023 10:38
clazaro

PAULDING COUNTY LIVE
UB Service Order

P 9
utworkor

Date Entered: 09/30/2022
Entered By: jfew
Reference: 525018
Account #: 00023221
CID: 269277
Default route: 88
Read Seq: 5745

District: UN Account Type: RS

CAIRNES, RICHARD BLAKE
143 SNOWDON WAY
VILLA RICA, GA 30180

Parcel: THE GEORGIAN G42
Location: 143 SNOWDON WAY

Desc: THE GEORGIAN G42
Subdiv: THE GEORGIAN

Lot: G42

Service : 1WTRRS-001 WATER - RESIDEN

Meter Info. Manuf/Serial
Read Meter IP 90081642 Other Meter
Installed Date 02/09/2022
of Dials: 6 Size: 3/4 Remote ID

Read Info.		Service Comment: R OF DR		Reading		Billed Usage	
Year/Mo	R	Reading	Billed Usage	Year/Mo	R	Reading	Billed Usage
2023/ 5	A	492	29	2022/11	A	322	28
2023/ 4	A	463	29	2022/10	A	294	29
2023/ 3	A	434	25	2022/ 9	A	265	27
2023/ 2	A	409	20	2022/ 8	A	238	20
2023/ 1	A	389	23	2022/ 7	A	218	33
2022/12	A	366	44	2022/ 6	A	185	48

Reason Code: LEAK LEAK
Serv Order Type: MISC MISCELLANEOUS SERVICE
Assigned To: WTR WATER DIVISION
Date Scheduled: 09/30/2022 Time Scheduled:

Addl Services: Manuf/Serial Reading

Comments: LEAK BEHIND THE STORMDRAIN PER ISABELLA CAIRNES 4-909-7895
DISP/JOEY-OC=FRI
9/29 RANDY/RAKESTRAW CHECKED 9/29 & AREA WAS DRY
//// SEE NOTES (JF)

Add'l Info:

9/30 JOEY=TESTED POSITIVE FOR CHLORINE. RL/ASAP, W/L, X-CHESTERFIELD C
T, CULD. LEAKING INTO RD. D-NOT SPIN. SPK W/ISABELLA ON SITE. 3/4 M#90
081642, R-0027617. R OF DR(JF)//// GLENN/RUFF/JOEY NO LEAK FOUND. DIAL
NOT SPINNING. LEFT D-HANGER. R-0027902. LANDSCAPE#525658(JF)

Work Completed By: _____ Date Completed: 10/03/2022
Completed Reason:

06/19/2023 10:38
clazaro

PAULDING COUNTY LIVE
UB Service Order

P 4
utworkor

Date Entered: 03/30/2023 District: UN Account Type: RS
 Entered By: pwdispatch
 Reference: 536652
 Account #: 00023221 CAIRNES, RICHARD BLAKE
 CID: 269277
 Default route: 88 143 SNOWDON WAY
 Read Seq: 5745 VILLA RICA, GA 30180

Parcel: THE GEORGIAN G42
 Location: 143 SNOWDON WAY

Desc: THE GEORGIAN G42
 Subdiv: THE GEORGIAN

Lot: G42

Service : 1WTRRS-001 WATER - RESIDEN

Meter Info. Manuf/Serial Manuf/Serial

Read Meter IP 90081642 Other Meter

Installed Date 02/09/2022

of Dials: 6 Size: 3/4 Remote ID

Read Info.		Service Comment: R OF DR		Year/Mo R		Reading		Billed Usage	
Year/Mo	R	Reading	Billed Usage	Year/Mo	R	Reading	Billed Usage	Year/Mo	R
2023/ 5	A	492	29	2022/11	A	322	28	2022/11	A
2023/ 4	A	463	29	2022/10	A	294	29	2022/10	A
2023/ 3	A	434	25	2022/ 9	A	265	27	2022/ 9	A
2023/ 2	A	409	20	2022/ 8	A	238	20	2022/ 8	A
2023/ 1	A	389	23	2022/ 7	A	218	33	2022/ 7	A
2022/12	A	366	44	2022/ 6	A	185	48	2022/ 6	A

Reason Code: LEAK LEAK
 Serv Order Type: MISC MISCELLANEOUS SERVICE
 Assigned To: WTR WATER DIVISION
 Date Scheduled: 03/30/2023 Time Scheduled:

Addl Services: Manuf/Serial Reading

Comments: ISABELLA CAIRNES 4-909-7895 LEAK NEAR STORMDRAIN
 DISP-DAILY (TRC)

////NOTES

Add'l Info:

//// 3/30 RYLOM/CADE=NO WTR AT ALL, NOTHING TO TEST. NO LEAK FOUND. D-
 NO SPIN, LEFT D/H. 3/4 M#90081642 R-0044896. R OF DR. (ZK)

Work Completed By: _____ Date Completed: 03/30/2023
 Completed Reason: _____

06/19/2023 15:15
clazaro

PAULDING COUNTY LIVE
UB Service Order

P 2
utworkor

Date Entered: 05/03/2023
Entered By: pwdispatch
Reference: 539007
Account #: 00023221
CID: 269277
Default route: 88
Read Seq: 5745

District: UN Account Type: RS

CAIRNES, RICHARD BLAKE
143 SNOWDON WAY
VILLA RICA, GA 30180

Parcel: THE GEORGIAN G42
Location: 143 SNOWDON WAY

Desc: THE GEORGIAN G42
Subdiv: THE GEORGIAN

Lot: G42

Service : 1WTRRS-001 WATER - RESIDEN

Meter Info. Manuf/Serial
Read Meter IP 90081642 Other Meter Manuf/Serial
Installed Date 02/09/2022
of Dials: 6 Size: 3/4 Remote ID

Read Info.		Service Comment: R OF DR		Reading		Billed Usage	
Year/Mo	R	Reading	Billed Usage	Year/Mo	R	Reading	Billed Usage
2023/ 5	A	492	29	2022/11	A	322	28
2023/ 4	A	463	29	2022/10	A	294	29
2023/ 3	A	434	25	2022/ 9	A	265	27
2023/ 2	A	409	20	2022/ 8	A	238	20
2023/ 1	A	389	23	2022/ 7	A	218	33
2022/12	A	366	44	2022/ 6	A	185	48

Reason Code: LEAK LEAK
Serv Order Type: MISC MISCELLANEOUS SERVICE
Assigned To: WTR WATER DIVISION
Date Scheduled: 05/03/2023 Time Scheduled:

Addl Services: Manuf/Serial Reading

Comments: PAULDING DOT 4-967-2985=WTR FLOODING YD & FLOWING INTO RD.
DISP-NICHOLS/OC 5/3. (TN)
6/19 KS EMAILED COOTS REQU FOR PWORK TODAY!!! (KS)
GAVE TO COOTS AS EM 5/3 (KS FOR TN) /// SEE NOTES

Add'l Info:

5/3 NICHOLS/OC=TESTED FOR CHLORINE, IT WAS NEGATIVE. CALLED RANDY=SEND COOTS TO REPAIR. SPK W/GARY ON SITE. 3/4 M#90081642, R-00483. R OF DR (TN) 5/4 KS EMAILED COPY/ORDER TO COOTS. (KS) /// 5/3/23 COOTS DUG DOWN TO REUSE LINE & CUT OFF @ VALVE TO STOP LEAK. 5/11/23 COOTS RETURNED & CUT OUT & REPLACED 10' OF 1" COPPER ON REUSE LINE. LANDSCAPE#541991. NO MTR INFO SINCE LEAK WAS ON REUSE LINE. (KS)

Work Completed By: _____ Date Completed: 05/11/2023
Completed Reason: _____